



ULR-TC578720000019066P

Test Report No. GGN/T(A)/20/018787A1

Dated: 2020-10-01



South Asia

Applicant : BACH TUYET COTTON CORPORATION
550 Au Co Street, Ward 10, Tan Binh District,
Ho Chi Minh City, Vietnam

Attention : /

Test Sample : Received on 2020-09-14 11:55 AM

Test Period : From 2020-09-14 to 2020-10-01

Sample Description : Sample A: Medical Mask (3 Ply Face Mask)

Color : White

Mfg./Exp. Date : Mfg. date: 09-09-2020, Expiry date: 09-09-2025

Sample Quantity : 6 Boxes (50 pcs/box)

Lot No./Batch No. : 0920

Country Of Origin : VIETNAM

Name of the Buyer / Destination : /

Testing Standard Followed : As per ASTM F2100-19, EN 14683:2019+AC:2019
The test specification is followed as per ASTM F2100 – 19, Level 3 Barrier and EN 14683:2019+AC:2019 type IIR

Note: 1. the submitted samples are Not Drawn by the Laboratory
2. Requested tests are performed

Sample Photo



By accepting this document, the customer hereby agrees and accepts the 'Terms & Conditions' and the relevant 'Testing & Certification Regulations' of TÜV SÜD South Asia Pvt. Ltd. which are available at Company's website at the link-<http://www.tuv-sud.in/in-en/resource-centre/terms-and-conditions>

The test report is electronically generated. Hence original signature is not required.

Note: (1) The results relate only to the items tested, (2) The test report shall not be reproduced except in full without the written approval of the laboratory, (3) Any use for advertising purposes must be granted in writing. This technical report may only be quoted in full. This report is the result of a single examination of the object in question and is not generally applicable evaluation of the quality of other products in regular production. For further details, please see testing and certification regulation, chapter A-3.4.

Laboratory:
TÜV SÜD South Asia Pvt. Ltd.
Plot no.373,
Udyog Vihar, Phase – II
Gurgaon,
Haryana - 122016

Phone : +91-0124-6199699
Fax : +91-0124-6199619
E-mail: tirtha.banerjee@tuv-sud.in
www.tuv-sud.in

Regd. Office:
TÜV SÜD South Asia
TÜV SÜD House
Off Saki Vihar Road
Saki Naka, Andheri (East)
Mumbai – 400072
India

ULR-TC578720000019066P

Test Report No. GGN/T(A)/20/018787A1

Dated: 2020-10-01



South Asia

Summary of Results

Sl. No.	Tests	Test Method	Specification	Observation	Conclusion
1.	Bacterial filtration efficiency (BFE)	ASTM F2101-19	$\geq 98\%$	98.36%	Pass
2.	Differential pressure (Breathability)	EN 14683:2019+AC:2019 (E) Annex C	$<6 \text{ mmH}_2\text{O}/\text{cm}^2$	$3.63 \text{ mmH}_2\text{O}/\text{cm}^2$	Pass
3.	Synthetic blood penetration (Splash resistance test)	ASTM F1862/F1862M - 17 (160 mm/Hg)	No visible penetration of synthetic blood at the end of test period. 29 masks out of 32 masks should pass the test to quality this parameter.	32 Specimens are Passing out of 32 Specimens	Pass
4.	Sub-micron Particulate Filtration Efficiency: (ASTM F2299/F2299M - 03 (Reapproved 2017))	ASTM F2299 (Average particle size (0.1μ))	$\geq 98\%$	98.00%	Pass
5.	Flammability	16 CFR Part 1610	Burning time should be ≥ 3.5 seconds to categorized as Class 1	Class1	Pass
6.	Bacterial filtration efficiency (BFE)	(EN 14683:2019+AC:2019(E) Annex B)	$\geq 98\%$	98.36%	Pass
7.	Differential pressure (Breathability)	EN 14683:2019+AC:2019 (E) Annex C	$<60 \text{ Pa}/\text{cm}^2$	$35.60 \text{ Pa}/\text{cm}^2$	Pass
8.	Synthetic blood penetration (Splash resistance test)	(ISO 22609:2004)	No visible penetration of synthetic blood at the end of test period. 29 masks out of 32 masks should pass the test to quality this parameter.	32 Specimens are Passing out of 32 Specimens	Pass
9.	Microbial Cleanliness (Bioburden)	EN ISO 11737-1:2018, Annex D	$\leq 30 \text{ CFU}/\text{g}$	$10 \text{ CFU}/\text{g}$	Pass

Conclusion:

1. This product achieved **Level 3 Barrier** according to ASTM F2100-19, standard specification for performance of materials used in medical face masks.

2. This product achieved **type IIR** according to EN 14683:2019+AC:2019, standard specification for performance of materials used in medical face masks.

The report no GGN/T(A)/20/018787 dated 2020-09-26 has been superseded. The test report is amended in terms of correction of Microbial Cleanliness test result.

Authorized By

Ashish Rai
(Authorised Signatory)

Authorized By

Ashutosh Kumar Pathak
(Authorised Signatory)

Laboratory:
TÜV SÜD South Asia Pvt. Ltd.
Plot no.373,
Udyog Vihar, Phase – II
Gurgaon,
Haryana - 122016

Phone : +91-0124-6199699
Fax : +91-0124-6199619
E-mail: tirtha.banerjee@tuv-sud.in
www.tuv-sud.in

Regd. Office:
TÜV SÜD South Asia
TÜV SÜD House
Off Saki Vihar Road
Saki Naka, Andheri (East)
Mumbai – 400072
India

ULR-TC578720000019066P

Test Report No. GGN/T(A)/20/018787A1

Dated: 2020-10-01



South Asia

Test Result(s):

1. Bacterial Filtration Efficiency: (ASTM F 2101 - 19)

Test Condition: Test Organism Used: Staphylococcus aureus ATCC 6538, Inoculum Size: 5×10^5 CFU/ml, Media Used: Tryptic soya agar, Dilution Medium Used: Peptone water, Incubation Period: $37 \pm 2^\circ\text{C}$ for 48 hrs, Area of test Specimen: 10 X 10 cm, Sample Exposure Side: Face Side, Flow Rate: 28.3 L/min, Mean particle size of challenge aerosol: 3.0 ± 0.3 micron

Observations:

Average Plate Count of Positive Control [A]	:	2542				
Average Plate Count of Negative Control [B]	:	0				
Specimens	:	1	2	3	4	5
Plate Count of Specimens [C]	:	42	41	41	43	40
Bacterial Filtration Efficiency (%), $E=[1-(C-B)/A]*100$:	98.34	98.38	98.38	98.30	98.42
Avg. Bacterial Filtration Efficiency (%)	:	98.36				
Requirement	:	$\geq 98\%$				
Conclusion	:	PASS				

Note: The test requirement is taken as per ASTM F2100 – 19, Level 3 Barrier

2. Differential Pressure (Breathability): (EN 14683:2019+AC:2019(E) Annex C)

Test Condition: Specimen Size: Diameter 25 mm (Area: 4.9 cm^2), Sample Exposure Side: Face Side, Flow Rate: 8 L/min, Airflow Direction: From the Inside of the Mask to the Outside of the Mask

Observations:

Specimens	:	1	2	3	4	5
Test Results ($\text{mmH}_2\text{O}/\text{cm}^2$)	:	3.63	3.93	3.55	3.45	3.59
Average Test Results ($\text{mmH}_2\text{O}/\text{cm}^2$)	:	3.63				
Requirement	:	$< 6\text{ mmH}_2\text{O}/\text{cm}^2$				
Conclusion	:	PASS				

Note: The test requirement is taken as per ASTM F2100 – 19, Level 3 Barrier

3. Synthetic blood penetration (Splash resistance test): (ASTM F1862/F1862M - 17)

Test Condition: Fluid Pressure: 160 mmHg

Observations:

Specimens	:	1	2	3	4	5	6	7	8
Test Results	:	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Specimens	:	9	10	11	12	13	14	15	16
Test Results	:	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Specimens	:	17	18	19	20	21	22	23	24
Test Results	:	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Specimens	:	25	26	27	28	29	30	31	32
Test Results	:	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Final Test Result	:	32 Specimens are Passing out of 32 Specimens							
Requirement	:	Minimum 29 specimens pass out of 32 specimens tested							
Conclusion	:	PASS							

Note: The test requirement is taken as per ASTM F2100 – 19, Level 3 Barrier

Laboratory:
TÜV SUD South Asia Pvt. Ltd.
Plot no.373,
Udyog Vihar,Phase – II
Gurgaon,
Haryana - 122016

Phone : +91-0124-6199699
Fax : +91-0124-6199619
E-mail: tirtha.banerjee@tuv-sud.in
www.tuv-sud.in

Regd. Office:
TÜV SUD South Asia
TÜV SUD House
Off Saki Vihar Road
Saki Naka, Andheri (East)
Mumbai – 400072
India



South Asia

4. Sub-micron Particulate Filtration Efficiency: (ASTM F2299/F2299M – 03 (Reapproved 2017))					
Test Condition: Particle Size: 0.1 micron					
Observations:					
Positive Control Particle Count [A]	:	18191			
Negative Control Particle Count [B]	:	2291			
Specimens	:	1	2	3	4
Particle Count With Specimens [C]	:	2441	2871	2443	2621
Particle Filtration Efficiency (%), $E = [1 - (C-B)/A] \times 100$:	99.17	96.81	99.16	98.18
Avg. Particle Filtration Efficiency (%)	:			98.00	
Requirement	:			>=98%	
Conclusion	:			PASS	
Note: The test requirement is taken as per ASTM F2100 – 19, Level 3 Barrier					

ULR-TC578720000019066P
Test Report No. GGN/T(A)/20/018787A1
Dated: 2020-10-01



5.0 FLAMMABILITY:
16 CFR 1610

Sample A -Upper				
Fabric Surface: Plain				
Preliminary Testing: Original: Lengthwise;				
	Original state		After Refurbishing	
	Flame spread(sec.)	Burn Code	Flame spread(sec.)	Burn Code
(1)	-	IBE	-	-
(2)	-	IBE	-	-
(3)	-	IBE	-	-
(4)	-	IBE	-	-
(5)	-	IBE	-	-
Average	-	-	-	-
(6)	-	-	-	-
(7)	-	-	-	-
(8)	-	-	-	-
(9)	-	-	-	-
(10)	-	-	-	-
Average	-	-	-	-
Flammability Classification: Class 1				
Refurbishing	N/A			
Remark:	<p>Class 1 - Normal Flammability Textiles meeting these requirements are generally accepted by the trade as having no unusual burning characteristics.</p> <p>Class 2 - Intermediate Flammability Textiles meeting these requirements are recognized by the trade as having flammability characteristics between normal and rapid and intense burning.</p> <p>Class 3 - Rapid and intense Burning Such textiles are considered dangerously flammable and recognized by the trade as being unsuitable for clothing because of their rapid and intense burning.</p> <p>IBE=Ignited but extinguished *IBE=Ignited but extinguished, denotes a burn that goes under the cord without breaking the cord -- Sec =Actual Burn Time Measured and Recorded by timing device DNI=Did not ignite BB = Base burns. SFuc = Surface flash under the code but does not break the cord. SFpw = Surface flash, part way SFpoi = Surface flash at point of impingement only. SFonly = Time in second, surface flash only. SFBB = Time in seconds, surface flash base burn. SFBBpoi = Time in seconds, surface flash base burn starting at the point of impingement.</p>			

Note: 1. Test after refurbishing is not applicable as per clause 16CFR 1610.35(a)(2)

Laboratory:
TUV SUD South Asia Pvt. Ltd.
Plot no.373,
Udyog Vihar,Phase – II
Gurgaon,
Haryana - 122016

Phone : +91-0124-6199699
Fax : +91-0124-6199619
E-mail: tirtha.banerjee@tuv-sud.in
www.tuv-sud.in

Regd. Office:
TUV SUD South Asia
TUV SUD House
Off Saki Vihar Road
Saki Naka, Andheri (East)
Mumbai – 400072
India

ULR-TC578720000019066P

Test Report No. GGN/T(A)/20/018787A1

Dated: 2020-10-01



South Asia

6. Bacterial Filtration Efficiency: (EN 14683:2019+AC:2019(E) Annex B)

Test Condition: Test Organism Used: Staphylococcus aureus ATCC 6538, Inoculum Size: 5×10^5 CFU/ml, Media Used: Tryptic soya agar, Dilution Medium Used: Peptone water, Incubation Period: $37 \pm 2^\circ\text{C}$ for 48 hrs, Area of test Specimen: 10 X 10 cm, Sample Exposure Side: Face Side, Flow Rate: 28.3 L/min, Mean particle size of challenge aerosol: 3.0 ± 0.3 micron

Observations:

Average Plate Count of Positive Control [A]	:	2542				
Average Plate Count of Negative Control [B]	:	0				
Specimens	:	1	2	3	4	5
Plate Count of Specimens [C]	:	42	41	41	43	40
Bacterial Filtration Efficiency (%), $E = [1 - (C - B)/A] \times 100$:	98.34	98.38	98.38	98.30	98.42
Avg. Bacterial Filtration Efficiency (%)	:	98.36				
Requirement	:	$\geq 98\%$				
Conclusion	:	PASS				

Note: The test requirement is taken as per EN 14683:2019+AC:2019 Type IIR

7. Differential Pressure (Breathability): (EN 14683:2019+AC:2019(E) Annex C)

Test Condition: Specimen Size: Diameter 25 mm (Area: 4.9 cm²), Sample Exposure Side: Face Side, Flow Rate: 8 L/min, Airflow Direction: From the Inside of the Mask to the Outside of the Mask

Observations:

Specimens	:	1	2	3	4	5
Test Results (Pa/cm ²)	:	35.55	38.57	34.80	33.84	35.24
Average Test Results (Pa/cm ²)	:	35.60				
Requirement	:	< 60 Pa/cm ²				
Conclusion	:	PASS				

Note: The test requirement is taken as per EN 14683:2019+AC:2019 Type IIR

8. Synthetic blood penetration (Splash resistance test): (ISO 22609:2004)

Test Condition: Fluid Pressure: 16.0 KPa (120 mmHg), Fluid Velocity: 550 cm/s

Observations:

Specimens	:	1	2	3	4	5	6	7	8
Test Results	:	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Specimens	:	9	10	11	12	13	14	15	16
Test Results	:	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Specimens	:	17	18	19	20	21	22	23	24
Test Results	:	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Specimens	:	25	26	27	28	29	30	31	32
Test Results	:	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Final Test Result	:	32 Specimens are Passing out of 32 Specimens							
Requirement	:	Minimum 29 specimens pass out of 32 specimens tested							
Conclusion	:	PASS							

Note: The test requirement is taken as per EN 14683:2019+AC:2019 Type IIR

Laboratory:
TÜV SÜD South Asia Pvt. Ltd.
Plot no.373,
Udyog Vihar, Phase – II
Gurgaon,
Haryana - 122016

Phone : +91-0124-6199699
Fax : +91-0124-6199619
E-mail: tirtha.banerjee@tuv-sud.in
www.tuv-sud.in

Regd. Office:
TÜV SÜD South Asia
TÜV SÜD House
Off Saki Vihar Road
Saki Naka, Andheri (East)
Mumbai – 400072
India

9. Microbial Cleanliness (Bioburden): (EN 14683:2019+AC:2019(E) Annex D / EN ISO 11737-1:2018)						
Test Condition: Plates are incubated for 3 days at 30°C and 7 days at (20 to 25)°C for TSA and SDA plates respectively.						
Observations:						
Specimens	:	1	2	3	4	5
Colonies of the TSA plate	:	10	12	8	12	9
Colonies of the SDA plate	:	1	2	0	2	3
Total Microbial Cleanliness (CFU/g)	:	11	14	8	14	12
Average Microbial Cleanliness (CFU/g)	:	10 CFU/g				
Requirement	:	<= 30 CFU/g				
Conclusion	:	PASS				
Note: The test requirement is taken as per EN 14683:2019+AC:2019 Type IIR						

Please Contact: For any Technical issued: Tirtha Banerjee at Tirtha.Banerjee@Tuv-sud.in ,For any Complaint: Krishna Deori at Krishna.Deori@tuv-sud.in

===== END OF REPORT =====





ULR-TC578720000017709P
Test Report No. GGN/T(A)/20/018786
Dated: 2020-09-26



South Asia

Applicant : BACH TUYET COTTON CORPORATION
550 Au Co Street, Ward 10, Tan Binh District,
Ho Chi Minh City, Vietnam

Attention : /

Test Sample : Received on 2020-09-14 11:55 AM

Test Period : From 2020-09-14 to 2020-09-26

Sample Description : Sample A: Medical Mask (4 Ply Face Mask)

Color : Blue

Mfg./Exp. Date : Mfg. date: 09-09-2020, Expiry date: 09-09-2025

Sample Quantity : 6 Boxes (50 pcs/box)

Lot No./Batch No. : 0920


Country Of Origin : VIETNAM

Name of the Buyer / Destination : /

Testing Standard Followed : As per ASTM F2100-19, EN 14683:2019+AC:2019
The test specification is followed as per ASTM F2100 – 19, Level 3 Barrier and EN 14683:2019+AC:2019 type IIR

Note: 1. the submitted samples are Not Drawn by the Laboratory
2. Requested tests are performed

Sample Photo



By accepting this document, the customer hereby agrees and accepts the 'Terms & Conditions' and the relevant 'Testing & Certification Regulations' of TÜV SÜD South Asia Pvt. Ltd. which are available at Company's website at the link-<http://www.tuv-sud.in/in-en/resource-centre/terms-and-conditions>

The test report is electronically generated. Hence original signature is not required.

Note: (1) The results relate only to the items tested, (2) The test report shall not be reproduced except in full without the written approval of the laboratory, (3) Any use for advertising purposes must be granted in writing. This technical report may only be quoted in full. This report is the result of a single examination of the object in question and is not generally applicable evaluation of the quality of other products in regular production. For further details, please see testing and certification regulation, chapter A-3.4.

Laboratory:
TÜV SÜD South Asia Pvt. Ltd.
Plot no.373,
Udyog Vihar, Phase – II
Gurgaon,
Haryana - 122016

Phone : +91-0124-6199699
Fax : +91-0124-6199619
E-mail: tirtha.banerjee@tuv-sud.in
www.tuv-sud.in

Regd. Office:
TÜV SÜD South Asia
TÜV SÜD House
Off Saki Vihar Road
Saki Naka, Andheri (East)
Mumbai – 400072
India

Summary of Results

Sl. No.	Tests	Test Method	Specification	Observation	Conclusion
1.	Bacterial filtration efficiency (BFE)	ASTM F2101-19	$\geq 98\%$	98.13%	Pass
2.	Differential pressure (Breathability)	EN 14683:2019+AC:2019 (E) Annex C	$<6 \text{ mmH}_2\text{O}/\text{cm}^2$	$3.38 \text{ mmH}_2\text{O}/\text{cm}^2$	Pass
3.	Synthetic blood penetration (Splash resistance test)	ASTM F1862/F1862M - 17 (160 mm/Hg)	No visible penetration of synthetic blood at the end of test period. 29 masks out of 32 masks should pass the test to qualify this parameter.	32 Specimens are Passing out of 32 Specimens	Pass
4.	Sub-micron Particulate Filtration Efficiency: (ASTM F2299/F2299M - 03 (Reapproved 2017))	ASTM F2299 (Average particle size 0.1μ)	$\geq 98\%$	98.32%	Pass
5.	Flammability	16 CFR Part 1610	Burning time should be ≥ 3.5 seconds to categorized as Class 1	Class1	Pass
6.	Bacterial filtration efficiency (BFE)	(EN 14683:2019+AC:2019(E) Annex B)	$\geq 98\%$	98.13%	Pass
7.	Differential pressure (Breathability)	EN 14683:2019+AC:2019 (E) Annex C	$<60 \text{ Pa}/\text{cm}^2$	$33.10 \text{ Pa}/\text{cm}^2$	Pass
8.	Synthetic blood penetration (Splash resistance test)	(ISO 22609:2004)	No visible penetration of synthetic blood at the end of test period. 29 masks out of 32 masks should pass the test to qualify this parameter.	32 Specimens are Passing out of 32 Specimens	Pass
9.	Microbial Cleanliness (Bioburden)	EN ISO 11737-1:2018, Annex D	$\leq 30 \text{ CFU}/\text{g}$	$17 \text{ CFU}/\text{g}$	Pass

Conclusion:

1. This product achieved **Level 3 Barrier** according to ASTM F2100-19, standard specification for performance of materials used in medical face masks.
2. This product achieved **type IIR** according to EN 14683:2019+AC:2019, standard specification for performance of materials used in medical face masks.

Authorized By



Neeraj Choubey
(Authorised Signatory)

Authorized By



Ashutosh Kumar Pathak
(Authorised Signatory)

Test Result(s):

1. Bacterial Filtration Efficiency: (ASTM F 2101 - 19)						
Test Condition: Test Organism Used: Staphylococcus aureus ATCC 6538, Inoculum Size: 5×10^5 CFU/ml, Media Used: Tryptic soya agar, Dilution Medium Used: Peptone water, Incubation Period: $37 \pm 2^\circ\text{C}$ for 48 hrs, Area of test Specimen: 10 X 10 cm, Sample Exposure Side: Face Side, Flow Rate: 28.3 L/min, Mean particle size of challenge aerosol: 3.0 ± 0.3 micron						
Observations:						
Average Plate Count of Positive Control [A]	:	2542.5				
Average Plate Count of Negative Control [B]	:	0				
Specimens	:	1	2	3	4	5
Plate Count of Specimens [C]	:	49	48	48	45	47
Bacterial Filtration Efficiency (%), $E = [1 - (C - B)/A] \times 100$:	98.07	98.11	98.11	98.23	98.15
Avg. Bacterial Filtration Efficiency (%)	:	98.13				
Requirement	:	$\geq 98\%$				
Conclusion	:	PASS				
Note: The test requirement is taken as per ASTM F2100 – 19, Level 3 Barrier						

2. Differential Pressure (Breathability): (EN 14683:2019+AC:2019(E) Annex C)						
Test Condition: Specimen Size: Diameter 25 mm (Area: 4.9 cm ²), Sample Exposure Side: Face Side, Flow Rate: 8 L/min, Airflow Direction: From the Inside of the Mask to the Outside of the Mask						
Observations:						
Specimens	:	1	2	3	4	5
Test Results (mmH ₂ O/cm ²)	:	3.23	3.33	3.18	3.61	3.51
Average Test Results (mmH ₂ O/cm ²)	:	3.38				
Requirement	:	<6 mmH ₂ O/cm ²				
Conclusion	:	PASS				
Note: The test requirement is taken as per ASTM F2100 – 19, Level 3 Barrier						

3. Synthetic blood penetration (Splash resistance test): (ASTM F1862/F1862M – 17)									
Test Condition: Fluid Pressure: 160 mmHg									
Observations:									
Specimens	:	1	2	3	4	5	6	7	8
Test Results	:	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Specimens		9	10	11	12	13	14	15	16
Test Results		Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Specimens		17	18	19	20	21	22	23	24
Test Results		Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Specimens		25	26	27	28	29	30	31	32
Test Results		Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Final Test Result	:	32 Specimens are Passing out of 32 Specimens							
Requirement	:	Minimum 29 specimens pass out of 32 specimens tested							
Conclusion	:	PASS							
Note: The test requirement is taken as per ASTM F2100 – 19, Level 3 Barrier									

4. Sub-micron Particulate Filtration Efficiency: (ASTM F2299/F2299M – 03 (Reapproved 2017))

Test Condition: Particle Size: 0.1 micron

Observations:

Positive Control Particle Count [A]	:	17186				
Negative Control Particle Count [B]	:	2439				
Specimens	:	1	2	3	4	5
Particle Count With Specimens [C]	:	2781	2541	2832	2986	2491
Particle Filtration Efficiency (%), $E = [1 - (C-B)/A] * 100$:	98.01	99.40	97.71	96.81	99.69
Avg. Particle Filtration Efficiency (%)	:	98.32				
Requirement	:	≥98%				
Conclusion	:	PASS				

Note: The test requirement is taken as per ASTM F2100 – 19, Level 3 Barrier

5.0 FLAMMABILITY:
16 CFR 1610

Sample A -Upper				
Fabric Surface: Plain				
Preliminary Testing: Original: Lengthwise;				
	Original state		After Refurbishing	
	Flame spread(sec.)	Burn Code	Flame spread(sec.)	Burn Code
(1)	-	IBE	-	-
(2)	-	IBE	-	-
(3)	-	IBE	-	-
(4)	-	IBE	-	-
(5)	-	IBE	-	-
Average	-	-	-	-
(6)	-	-	-	-
(7)	-	-	-	-
(8)	-	-	-	-
(9)	-	-	-	-
(10)	-	-	-	-
Average	-	-	-	-
Flammability Classification: Class 1				
Refurbishing	N/A			
Remark:	<p>Class 1 - Normal Flammability Textiles meeting these requirements are generally accepted by the trade as having no unusual burning characteristics.</p> <p>Class 2 - Intermediate Flammability Textiles meeting these requirements are recognized by the trade as having flammability characteristics between normal and rapid and intense burning.</p> <p>Class 3 - Rapid and intense Burning Such textiles are considered dangerously flammable and recognized by the trade as being unsuitable for clothing because of their rapid and intense burning.</p> <p>IBE=Ignited but extinguished *IBE=Ignited but extinguished, denotes a burn that goes under the cord without breaking the cord -- Sec =Actual Burn Time Measured and Recorded by timing device DNI=Did not ignite BB = Base burns. SFuc = Surface flash under the code but does not break the cord. SFpw = Surface flash, part way SFpoi = Surface flash at point of impingement only. SFonly = Time in second, surface flash only. SFBB = Time in seconds, surface flash base burn. SFBBpoi = Time in seconds, surface flash base burn starting at the point of impingement.</p>			

Note: 1. Test after refurbishing is not applicable as per clause 16CFR 1610.35(a)(2)

6. Bacterial Filtration Efficiency: (EN 14683:2019+AC:2019(E) Annex B)						
Test Condition: Test Organism Used: Staphylococcus aureus ATCC 6538, Inoculum Size: 5 × 10 ⁵ CFU/ml, Media Used: Tryptic soya agar, Dilution Medium Used: Peptone water, Incubation Period: 37 ± 2°C for 48 hrs, Area of test Specimen: 10 X 10 cm, Sample Exposure Side: Face Side, Flow Rate: 28.3 L/min, Mean particle size of challenge aerosol: 3.0 ± 0.3 micron						
Observations:						
Average Plate Count of Positive Control [A]	:	2542.5				
Average Plate Count of Negative Control [B]	:	0				
Specimens	:	1	2	3	4	5
Plate Count of Specimens [C]	:	49	48	48	45	47
Bacterial Filtration Efficiency (%), E=[1-(C-B)/A]*100	:	98.07	98.11	98.11	98.23	98.15
Avg. Bacterial Filtration Efficiency (%)	:	98.13				
Requirement	:	≥98%				
Conclusion	:	PASS				
Note: The test requirement is taken as per EN 14683:2019+AC:2019 Type IIR						

7. Differential Pressure (Breathability): (EN 14683:2019+AC:2019(E) Annex C)						
Test Condition: Specimen Size: Diameter 25 mm (Area: 4.9 cm ²), Sample Exposure Side: Face Side, Flow Rate: 8 L/min, Airflow Direction: From the Inside of the Mask to the Outside of the Mask						
Observations:						
Specimens	:	1	2	3	4	5
Test Results (Pa/cm ²)	:	31.71	32.67	31.22	35.45	34.45
Average Test Results (Pa/cm ²)	:	33.10				
Requirement	:	<60 Pa/cm ²				
Conclusion	:	PASS				
Note: The test requirement is taken as per EN 14683:2019+AC:2019 Type IIR						

8. Synthetic blood penetration (Splash resistance test): (ISO 22609:2004)									
Test Condition: Fluid Pressure: 16.0 KPa (120 mmHg), Fluid Velocity: 550 cm/s									
Observations:									
Specimens	:	1	2	3	4	5	6	7	8
Test Results	:	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Specimens	:	9	10	11	12	13	14	15	16
Test Results	:	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Specimens	:	17	18	19	20	21	22	23	24
Test Results	:	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Specimens	:	25	26	27	28	29	30	31	32
Test Results	:	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Final Test Result	:	32 Specimens are Passing out of 32 Specimens							
Requirement	:	Minimum 29 specimens pass out of 32 specimens tested							
Conclusion	:	PASS							
Note: The test requirement is taken as per EN 14683:2019+AC:2019 Type IIR									

9. Microbial Cleanliness (Bioburden): (EN 14683:2019+AC:2019(E) Annex D / EN ISO 11737-1:2018)						
Test Condition: Plates are incubated for 3 days at 30°C and 7 days at (20 to 25)°C for TSA and SDA plates respectively.						
Observations:						
Specimens	:	1	2	3	4	5
Colonies of the TSA plate	:	24	19	28	25	20
Colonies of the SDA plate	:	4	5	4	3	2
Total Microbial Cleanliness (CFU/g)	:	28	24	32	28	22
Average Microbial Cleanliness (CFU/g)	:	17CFU/g				
Requirement	:	<= 30 CFU/g				
Conclusion	:	PASS				
Note: The test requirement is taken as per EN 14683:2019+AC:2019 Type IIR						

Please Contact: For any Technical issued: Tirtha Banerjee at Tirtha.Banerjee@Tuv-sud.in ,For any Complaint: Krishna Deori at Krishna.Deori@tuv-sud.in

===== END OF REPORT =====

